

**OFFICE OF THE CMD (WZ)**  
**M.P. PASCHIM KSHETRA VIDYUT VITARAN CO. LTD.,**  
**GPH COMPOUND, POLOGROUND, INDORE**  
(EPABX Phone No: 0731-2422045, 2423263, 2422544, 2423577 Extn. 151 & 303 Fax No: 2423300)

---

No. CMD/WZ/06/PUR/7550

Indore, date: **29.04.2010**

To,

**All Bidders**

**Sub:- Tender specification No. CMD/WZ/06/PUR/426 due on 06.05.2010 for supply of ISI Marked, LT CT operated three phase 4 wire LCD display Meter with AMR compatibility, class 1.0 or better along with GPRS enabled GSM modem suitable for meter end with software and accessories for above meter**

Ref:- M/s. Landis + Gyr Ltd., Kolkata's letter No. L&G/MPPKVVCL/Apr/TS/426/01 dated 23.04.2010.

Dear Sir's,

With reference to above tender specification & your letter dated 23.04.2010, the clarifications are as under:-

Sr. No.	Clause No.	MPPKVVCL, specification	Clarification required	Remark
1	3 of Section-III (A), Technical specification	Applicable standard IS: 13779 & CBIP Tech Report-88 for class 1.0 accuracy	As the tender specification also asks for better accuracy class of meters, therefore in case of 0.5S accuracy the applicable standard shall be IS: 14697. Please confirm acceptability of the same.	Yes, if offered meter is of better accuracy than class 1 the applicable standard shall be IS: 14697
2	20 of Section-III (A), Technical specification	Communication Port: The meter shall confirm to either open protocol standard IEC-62056 or meters should be API compliant. In case of proprietary protocol details should be submitted by the supplier	We have meters complying to open protocol IEC 62056 and proprietary protocol like IEC 62056-21. IEC 62056 will be exactly as per the BIS Draft Companion specification which will not support many desired features as per the requirement of your tender specification. Please confirm whether we should offer the meter compliant to IEC 62056 or IEC 62056-21.	The offered meter should support all the features as per the requirement of tender specification
3	11 of Section-III (A), Technical specification	Load Survey: Energy Import & export mode	Export Energy mode is not applicable for LT CT operated meters. Request you to delete this clause from your tender specification.	Accepted load survey energy export mode is not required

There is no change in due date of submission at this stage.

Superintending Engineer (Pur)  
O/o CMD (WZ), MPPKVVCL,  
Indore