

OFFICE OF THE CMD (WZ)
M.P. PASCHIM KSHETRA VIDYUT VITARAN CO. LTD.,
GPH COMPOUND, POLOGROUND, INDORE

(EPABX Phone No: 0731-2422045, 2423263, 2422544, 2423577 Extn. 151 & 303 Fax No: 2423300)

No. CMD/WZ/06/PUR/8764

Indore, date: 14.05.2010

To,
All Bidders

Sub:- Tender specification No. CMD/WZ/06/PUR/425 & 426 due on 20.05.2010.

- Ref:- (i) M/s. Omne Agate Systems Pvt. Ltd., Chennai's letter No. MPPKVVCL / 249 / 2010 dated 03.05.2010.
(ii) M/s. Secure Meters Limited, Udaipur's letter No. SML / MPPKVVCL / KML / TS / 426 / 06052010 dated 06.05.2010.

Dear Sir's,

With reference to above tender specification & your letter dated 03.05.2010, the clarifications are as under:-

Sr. No.	Name of firms	Clause No.	Description	Clarification	Remark
TS No. CMD/WZ/06/PUR/425 due on 20.05.2010 for procurement of ISI Marked, LT three phase four wire, 240 volt, class 1.0, 20-80 Amp or higher capacity, designed for over loading up to 120 Amps with accuracy guaranteed up to 120 amp static (electronic) trivesctor whole current LCD display meters with AMR compatibility along with GPRS enabled GSM modem suitable for meter end with software and accessories for above meter.					
1	M/s. Omne Agate System Pvt. Ltd., Chennai	Page No. 23 clause No. 12.2 & GTP 17	Terminal hole shall be minimum 11 mm	We have terminal hole size of 9.5 mm only. Whether it is acceptable or not?	Not acceptable
2		GTP 20 (iv)	Type of hinged undetachable terminal cover & size / thickness of hinges Book (Door) type opening	We have provision of front (door) type opening only. Whether it is acceptable or not?	Not acceptable
3		Clause No. 5.12.4	Meters shall be programmed for auto display of billing parameters with provision of '15 Seconds time display of each billing parameters.	Mention what are all the parameters programmed for Billing	Billing parameter as per clause 5.7 (a)
4		In Modem Page No. 31 Clause No. 4 (d)	The modem shall be housed in an enclosure of eng. Plastic.	We have provision for aluminum case only	Not acceptable
5		In GTP Meter page No. 44 Clause No. 22	(i) Phase-neutral interchanged (ii) Main & load wire are interchanged (iii) Load is not terminated back and current is drawn through local path.	Whether these conditions are single phase meter or three phase meter requirement	The clause is well expletory

Sr. No.	Name of firms	Clause No.	Description	Clarification	Remark
TS No. CMD/WZ/06/PUR/426 due on 20.05.2010 for procurement of ISI Marked, LT CT operated three phase 4 wire LCD display Meter with AMR compatibility, class 1.0 or better along with GPRS enabled GSM modem suitable for meter end with software and accessories for above meter.					
1	M/s. Omne Agate System Pvt. Ltd., Chennai	Page No. 17 clause No. 7.C (v) & 11	(i) Load survey for last 35 days with 15 minutes interval. (ii) It should be possible to store previous data of at least 31 days x 4 parameters for interval of 15 minutes or 62 days x 4 parameters for interval of 30 minutes or 62 days x 2 parameters for interval of 15 minutes etc.	Confirm load survey storage whether 35 days or 31 days	It should be as per tender specifications.
2		Clause No. 11	(i) Active Demand and Energy Import / Export Mode (ii) Apparent Demand and Energy Import / Export Mode (iii) RKVAH Import while KWH import Demand and Energy (iv) RKVAH Export while KWH import Demand and Energy (v) RKVAH Import while KWH export Demand and Energy (vi) RKVAH Export while KWH export Demand and Energy	This is HT meter requirements, Is it required for LT CT Meter?	The load survey energy export made is not required
3		Clause No. 12.4	Meter shall be programmed for auto display of billing parameters with provision of '15 seconds time display of each billing parameters'.	Mention what are all the parameters programmed for Billing	As per technical specification clause No. 7 (a)
4		In Modem Page No. 31 Clause No. 4 (d)	The mode shall be housed in an enclosure of engg. Plastic.	We have provision of aluminum case only	It should be as per tender specifications
5		In GTP Meter Page No. 42	(i) Indication for tamper conditions (a) Phase – neutral interchanged (b) Main & load wire are interchanged (c) Load is not terminated back and current is drawn through local path (d) Earth loading earth indication	Whether these conditions are single phase meter or three phase meter requirement?	Temper conditions are of LT CT Meter
1	M/s. Secure Meters Limited, Udaipur	TS No. 426	Request to amend the technical specification in compliance with IEC 62056 open protocol issued by CPRI	-	The offered meter should support all the features as per the requirement of tender specification.

Superintending Engineer (Pur)
O/o CMD (WZ), MPPKVCL,
Indore