

OFFICE OF THE CMD (WZ)
M.P. PASCHIM KSHETRA VIDYUT VITARAN CO. LTD.,
GPH COMPOUND, POLOGROUND, INDORE

(EPABX Phone No: 0731-2422045, 2423263, 2422544, 2423577 Extn. 144 & 303 Fax No: 2423300)

No. CMD/WZ/06/PUR/2988

Indore, date: 10.02.2011

To,

All Bidders
As per list enclosed

Sub:- Tender specification No. CMD/WZ/06/PUR/T. Enq-482 due for opening on 15.02.2011 for supply of 3 Phase, 4/3 Wire HT Meters, 63.5 Volt/110 Volts, 1 Amp, 0.2S Accuracy Class Along With GSM /GPRS Enabled Modem Suitable for Meter end with Software and Accessories.


Ref:- (i) M/s. Secure Meters Ltd., Udaipur's letter No. SML/BPL/Indore/TS-482/01 dated 28.01.2011.
(ii) M/s. Wallaby Metering Systems Pvt. Ltd., Chennai's letter No. WMS/MKTG/MPPKVVCL/G-/2010-11 dated 28.01.2011.

Dear Sir's,

With reference to above tender specification & the various clarification asked in respect of the tender conditions / specifications, the clarifications are as under:-

Sr. No.	Clause No. & requirement	Amendment / clarification with justification	Clarification
Point Raised by M/s. Secure Meters Ltd., Udaipur			
1	4.3.10 Display Parameter	We request to reduce the display parameters and for history only import energy & demand may be asked Justification: All the parameters can not be selected at display, however all the parameters shall be available in the meter memory.	As per tender specification
2	4.3.11.XI Daily Midnight Energy Active, reactive & Apparent	Please note that Active Import & Export, Reactive Import @ active Import, reactive export @active export, Apparent Import & apparent Export shall be available in meter memory. Please confirm	Clause is self explanatory
3	6.1 of III B In bound Dialing	We request to delete the clause as the same is not required. Since the offered modem shall be compatible with RAPDRP requirement to be successfully integrated with RAPDRP scheme, we request that the clause may be removed	In bound is required as per tender specification
4	6.3 of III B Event Based Dialing	We request to delete the clause as the same is not required. Since the offered modem shall be compatible with RAPDRP requirement to be successfully integrated with RAPDRP scheme, we request that the clause may be removed.	In light of SRS document of RAPDRP SMS in the event of outage or tamper event is also permissible.
5	Statutory Levies, Schedule-I	We request that Any statutory variation in taxes and duties shall be in the account of purchaser's during the contractual delivery period. The statutory variations are beyond the control of bidder and therefore the same shall be to the account of purchaser.	As per tender condition
6	Payment terms	We request that the payment against the supplies shall be released within 45 days and should not be linked with type test, payment que. In case of delay beyond 60 days interest may be paid to the supplier.	As per tender condition
7	Date extension	We request to issue the amendment in the above clauses and also to extend the due date by at least two to three weeks to enable us to submit our best techno commercial offer.	Due date has been extended till 15.02.2011

Point Raised by M/s. Wallaby Metering Systems Pvt. Ltd., Chennai			
8	Page 7 of 83 Section-I, Qualifying Criterion General -(i)	That they are manufacturer having experience of at least 3 years of manufacturing and has designed, tested & already supplied at least 1000 Nos. HT Meter in past 3 years to SEBs, power utilities of rating 3 Phase, 4/3 Wire HT meters, 63.5 Volts/110 Volts, 5 Amp / 1 Amp, 0.5S/0.2S accuracy class Wallaby Request Ammend As That they are manufacturer / JVC / Parent Company having experience of at least 3 years of manufacturing and has designed, tested & already supplied at least 1000 Nos. HT Meter in past 3 years to SEBs, power utilities of rating 3 Phase, 4/3 Wire HT meters, 63.5 Volts / 110 Volts, 5 Amp / 1 Amp, 0.5S/0.2S accuracy class	As per tender condition
9	Page 26 of 83 Section III(A) Technical Specification (16)	With the every lot of 100 Meters or part thereof the bidder are required to supply one no. common MRI (Meter reading instrument) of reputed make free of cost CMRI should conform to technical specification given in annexure-VI (B) and minimum guaranteed technical particulars given in schedule VI(B) in this tender specification Wallaby Request Do Bidder has to supply MRI at free of cost for required quantity mentioned in tender?	As per tender specification / conditions.
10	Page 7 of 83 Section-I, Qualifying Criterion Technical -(IV)	The offers should be fully technically acceptable i.e. the sample meter should meet all the constructional features & technical requirements as specified in the technical specifications in Section-III and GTP (Schedule-II). The sample meter shall be got tested in any NABL accredited lab for relevant acceptance test as per IS: 14697 with test of accuracy up to I _{max} 2Amp & Test of MD requirement as per sliding window principal as per tender specification for evaluation & price bid of only those bidders whose sample meter has successfully passed above tests shall be opened. The cost of testing is to be borne by the MPPKVCL, however in case the sample meter do not successfully pass the above tests at NABL accredited lab, the testing charges of such sample meters so incurred shall have to be born by the respective bidder for which every bidder will have to submit the irrevocable Bank Guarantee of Rs. 80,000/- from Nationalized Bank in favour of Chief Engineer (Corp. Office – Pur), MPPKVCL, Indore / or DD of Rs. 80,000/- in favour of Sr. AO, MPPKVCL, Indore. No offer will be accepted without such BG / DD & the BG / DD will have to be submitted along with the EMD in the same envelop. The Company reserves the right to test sample meter in company's lab also. Wallaby Request No of samples, if one sample 3 Phase / 3 Wire of 3 Phase / 4 Wire?	One sample of each category is required.


 Superintending Engineer (Pur)
 O/o CMD (WZ), MPPKVCL,
 Indore