

OFFICE OF THE CMD (WZ)

M.P. PASCHIM KSHETRA VIDYUT VITARAN CO. LTD.,

GPH COMPOUND, POLOGROUND, INDORE

(EPABX Phone No: 0731-2422045, 2423263, 2422544, 2423577 Extn. 144 & 303 Fax No: 2423300)

No. CMD/WZ/06/PUR/ 2037

Indore, date: 29 JAN 2011


CORRIGENDUM No. 1

TS No. CMD/WZ/06/PUR/483 for Procurement of Single Phase 2 Wire, 240 Volts, 5-30 Amp Static Whole Current Energy Meter with Polycarbonate Transparent Meter Cover

Following corrections have been incorporated in Clause No. 16.4 Technical Specification & Clause No. 17 GTP of tender specification No. **TS-483 due for opening on 22.02.2011.**

- (i) **Clause No. 16.4 (Page 19 of 74) of Technical specification:-** The line in second para "The meter shall possess a suitable fast reliable Infra-red / RF Communication port for automatic transfer of data from Meter to CMRI" is deleted.
- (ii) **Clause No. 17 (Page 40 of 74) of GTP** may be read as "Whether meter is provided with optical port for data downloading"

Other terms and conditions of the tender shall remain unchanged and applicable.


Chief Engineer (Corporate Office)
O/o CMD (WZ), MPPKVCL,
Indore