



**Madhya Pradesh Paschim Kshetra Vidyut
Vitaran Co. Ltd., Indore**
(A wholly-owned Govt. of MP Undertaking)
GPH, Polo Ground, Indore 452003

CMD/WZ/COM/SE(BD)/11-12/ 2686

Indore Dtd. 3/02/2012

CORRIGENDUM

**Tender Specification No. CMD/ SE(BD)/ Distribution of Elect./
2011/04/ Ujjain City/ 20780 dated 30.09.2011**

With reference to the above tender, all interested bidders may note that the following amendments and clarifications have been made in the Bidding Documents for selection of Input Based Distribution Franchisee for Ujjain City as mentioned below:-

A. Amendments

1. Request for Proposal (RFP)

Sr. No	Clause No.	Original Clause	Amended Clause
1.	Clause 10.1.1. (Technical Criteria (a) relating to the Experience in Power Sector/ Experience in handling Consumer Base)	The technical criteria shall be met by every Bidder. In case of Bid submitted by a Consortium, the technical criteria stated in Clause 10.1(a) shall necessarily be met by the Lead Member of the Consortium.	The technical criteria shall be met by every Bidder. In case of Bid submitted by a Consortium, the technical criteria stated in Clause 10.1(a) shall be met by any Member of the Consortium who has and shall continue to have equity share of at least 26% in the SPV, for a period as specified in the DFA.

2. Distribution Franchisee Agreement (DFA)

Sr. No.	Article No.	Original Article	Amended Article
1	Definition	<p>“SAIDI” or “System Average Interruption Duration Index” shall mean the average duration in hours of sustained (each longer than 5 minutes) interruptions per Consumer during the year and shall be computed as follows:</p> $\text{SAIFI} = \frac{\sum_{i=1}^n (\text{Bi} \times \text{Ni})}{\text{Nt}}$ <p>where, Bi = Total duration of all sustained interruptions (each longer than 5 minutes) on ‘i’th 11kV feeder for the year Ni = Connected load of ‘i’ th 11kV feeder affected due to each interruption Nt = Total connected load at 11kV in the Franchisee Area n = Number of 11kV feeders in the Franchisee Area</p>	<p>It is clarified that the original formula for calculation of SAIDI in the RfP is now modified to be read as:</p> $\text{SAIDI} = \frac{\sum_{i=1}^n (\text{Bi} \times \text{Ni})}{\text{Nt}}$ <p>where, Bi = Total duration of all sustained interruptions (each longer than 5 minutes) on ‘i’th 11kV feeder for the year Ni = Connected load of ‘i’ th 11kV feeder affected due to each interruption Nt = Total connected load at 11kV in the Franchisee Area n = Number of 11kV feeders in the Franchisee Area</p>

B. Clarifications

1. Request for Proposal (RFP)

Bidders furnishing documentary evidences have to provide prescribed formats duly certified by any full time Director of the company. However, in cases where a company does not have a full time Director, in such cases, the certification can be provided by a Manager of the Company duly appointed as per the provisions of the Companies Act, 1956, which is permissible subject to the following two conditions:

- (a) The Company should confirm through a copy of Board Resolution, attested by the Company Secretary, that the concerned person is appointed as Manager as defined under the Companies Act, 1956 for the purpose in question, and
- (b) A certification from the Company Secretary attesting to the fact that the Company does not have a whole-time Director.

2. Distribution Franchisee Agreement (DFA)

Sr. No.	Article No.	Description	Clarification(s)
1.	Definition of SAIFI and SAIDI	<p>“SAIFI” or “System Average Interruption Frequency Index” shall mean the average number of sustained (each longer than 5 minutes) interruptions during the year</p> <p>“SAIDI” or “System Average Interruption Duration Index” shall mean the average duration in hours of sustained (each longer than 5 minutes) interruptions per Consumer during the year a.....</p>	It may be noted by interested bidders that the figures for SAIFI and SAIDI to be computed to meet the prescribed targets shall exclude transmission outage, load shedding and planned outages .
2.	Article 4.4.1	Determination of Arrears separately for Disconnected and connected Consumers for the period up to the Effective Date, including the arrears accrued during the last Consumer billing cycle immediately preceding the Effective Date . The Arrears under litigation, vigilance and	It is further clarified that the Arrears under litigation, vigilance and audit recoveries shall be finalized, jointly, within seven (7) days from the Effective Date.

Sr. No.	Article No.	Description	Clarification(s)
		audit recoveries shall be separately mentioned. The arrears so determined shall be considered to be final by the end of the Transition Period, after consideration of collection during such period as per the provision of Article 12.5(ii);	
3.	Article 13.1 (ii) & (iii)	The Distribution Franchisee shall be solely responsible for undertaking all operations and maintenance related activities in relation to the Distribution Assets, the Distribution Franchisee Assets and the Distribution System in the Franchisee Area. The maintenance of the Distribution Assets, the Distribution Franchisee Assets and the Distribution System shall be carried out as per the Performance Standards prescribed under the Electricity Supply Code, 2004 as in force from time to time, and as per the directions/ orders of MPERC and standards as prescribed by other statutory authorities as applicable to the Distribution Licensee. Any expenditure incurred by the Distribution Franchisee on repair and	It is further clarified that the cost of replacement of Distribution Assets by the Distribution Franchisee shall be treated as capital expenditure of the Distribution Franchisee.

Sr. No.	Article No.	Description	Clarification(s)
		<p data-bbox="646 264 1036 548">maintenance of such Assets shall be treated as operation and maintenance cost of Franchisee. The operation and maintenance related activities shall include:</p> <p data-bbox="646 569 1036 663">(i) Maintenance of the transformers.....</p> <p data-bbox="646 684 1036 999">(ii) Replacement of defective Meters within the prescribed time frame as stipulated in Electricity Supply Code, 2004 as in force from time to time;</p> <p data-bbox="646 1020 1036 1587">(iii) Replacement of any failed transformers within the prescribed time frame and maintenance of sufficient rolling stock of transformers and other necessary materials so as to comply with the norms prescribed by MPERC with respect to time and quality;</p>	

Sd/-
S.E (Com-Franchisee)
MPPKVCL, Indore