

**CLARIFICATION DTD.-14.10.2011**

**In the matter of EOI No.CMD/WZ/06/PUR/20764 Dtd.30.09.2011.**

In response to the queries raise by M/s Aster Private Limited, Hyderabad – 500062, vide L. No. APL/T&D/Dist./MPPKVCL/11-12/6251 Dtd.07.10.2011, the point wise clarification is given below:

| <b><u>Query</u></b>  | <b><u>Clarification</u></b>        |
|--|------------------------------------|
| 1. Please Confirm the tentative length of line to be constructed on monopoles.                                     | 33KM. (approx.)                    |
| 2. Please clarify the type & size of 33KV XLPE (UG) cable and arrange the specifications.                          | 400 Sq.mm.                         |
| 3. Please confirm along with the line ground wires Are required or not.  | NIL                                |
| 4. Please confirm whether sectionalizes quantity (4 Nos) is Given for 1 km length of line or total length of line. | Total                              |
| 5 Please provide the route survey details i.e. inline, angle and tension poles per KM length.                      | Arrange Survey (refer detaled EOI) |

Rest as per EMI

SE (Pur – Proj)